

**CERTIFICATES SHALL BE ISSUED UPON THE FOLLOWING
CONDITIONS:**

- **ALL PROTECTIVE DEVICES AND EQUIPMENT REQUIRED TO BE INSTALLED BY THE REGULATIONS WILL CONTINUE TO BE OPERATIONAL AS REQUIRED BY THE REGULATIONS – UCC 5:23-2.24(a)5**
- **ALL HARDWIRED SMOKE DETECTORS MUST REMAIN HARDWIRED**
- **1 SMOKE DETECTOR ON EACH LEVEL**
- **1 SMOKE DETECTOR IN THE BASEMENT (IF YOU HAVE A BASEMENT)**
- **1 SMOKE DETECTOR WITHIN 10 FEET OF ALL BEDROOM DOORS ON ALL LEVELS**
- **1 CARBON MONOXIDE DETECTOR WITHIN 10 FEET OF ALL BEDROOM DOORS ON ALL LEVELS**
- **1 FIRE EXTINGUISHER 2A:10B:C WITHIN 10 FEET OF THE KITCHEN OR IN THE KITCHEN. FIRE EXTINGUISHER MUST BE MOUNTED NO HIGHER THAN 5 FEET FROM THE FLOOR, AND CAN NOT BE BEHIND ANY DOORS**
- **FAILURE TO HAVE THE ABOVE IN PLACE WILL REQUIRE YOU TO MAKE ANOTHER APPOINTMENT**
- **ALL CANCELLATIONS MUST BE MADE IN WRITING 24 HOURS IN ADVANCE AND CAN BE FAXED TO 732-723-9658**
- **ALL REINSPECTIONS/CANCELLATIONS HAVE TO BE DONE WITHIN 30 DAYS. ANY INSPECTION CONDUCTED AFTER 30 DAYS WILL REQUIRE FULL PAYMENT SCHEDULE AS LISTED ON APPLICATION**
- **CHECK SMOKE DETECTORS - IF 10 YEARS OLD OR MORE THEY MUST BE CHANGED OR YOU WILL FAIL**