

SMOKE DETECTOR/CARBON MONOXIDE REQUIREMENTS

CERTIFICATE SHALL BE ISSUED UPON THE FOLLOWING CONDITIONS:

ALL PROTECTIVE DEVICES AND EQUIPMENT REQUIRED TO BE INSTALLED BY THE REGULATIONS WILL CONTINUE TO BE OPERATIONAL AS REQUIRED BY THE REGULATIONS
UCC 5:23-2.24(a)5

-
- ONE SMOKE DETECTOR ON EACH LEVEL, INCLUDING THE BASEMENT (IF APPLICABLE). A DETECTOR MUST BE WITHIN 10 FEET OF ANY BEDROOM ON ALL LEVELS
 - ONE CARBON MONOXIDE DETECTOR WITHIN 10 FEET OF ANY BEDROOM
 - ONE FIRE EXTINGUISHER – MUST BE THE **2A:10B:C** – WITHIN 10 FEET OF THE KITCHEN OR IN THE KITCHEN – FIRE EXTINGUISHER MUST BE MOUNTED NO HIGHER THAN 5 FEET FROM THE FLOOR, AND CAN NOT BE BEHIND ANY DOORS OR CABINETS
 - BATTERY-OPERATED SMOKE DETECTORS – MUST BE TEN YEAR SEALED BATTERY-OPERATED SMOKE DETECTORS
 - HARDWIRED SMOKE DETECTORS MUST REMAIN HARDWIRED AND IF MORE THEN TEN YEARS OLD MUST BE REPLACED.

FAILURE TO HAVE THE ABOVE IN PLACE WILL REQUIRE YOU TO MAKE ANOTHER APPOINTMENT AND SUBMIT A FEE OF \$35.00

ALL CANCELLATIONS MUST BE MADE IN WRITING 24 HOURS IN ADVANCE AND CAN BY FAXED TO 732-723-9658

ALL REINSPECTIONS/CANCELLATIONS HAVE TO BE DONE WITHIN 30 DAYS. ANY INSPECTION CONDUCTED AFTER 30 DAYS WILL REQUIRE FULL PAYMENT SCHEDULE AS LISTED ON APPLICATION.